

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:55 am

PWS ID: UTAH09006 **Name:** HENRIEVILLE TOWN WATER SYSTEM
Legal Contact: HENRIEVILLE **Rating:** Approved
 BRETT HARVEY CHYNOWETH **Rating Date:** 03/10/1980
Address: BOX 125 **Activity Status:** Active
 HENRIEVILLE, UT 84736
Phone Number: 435-679-8713
City Served (Area):
County: GARFIELD COUNTY
System Type: Community **Last Inv Update:** 05/28/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 05/27/2008 **Total Dsgn Cap:**
Population: 300 **Surveyor:** MARK BERTELSON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	CHYNOWETH, BRETT HARVEY	MANAGER	435-679-8713	435-616-3499	bchynoweth@rwau.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	150
Commercial	Metered	0	1
			151 Total Svc Connections

Storage

Total Storage: 375,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST003	200 K STORAGE	Reservoir	200,000	Concrete		A	NO
ST001	100 K STORAGE	Ground	100,000 GAL	Concrete		A	NO
ST002	75 K STORAGE	Ground	75,000 GAL	Concrete		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP003	HORIZONTAL WELL SPRING CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SEISMIC WELL	Inactive	WL		75 GPM		Yes	GW	Other		
WS002	HENRIEVILLE SPRING	Inactive	SP				Yes	GW	Other		
WS003	HORIZONTAL WELL SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS004	S HORIZONTAL WELL	Inactive	WL				No	GW	Other		
WS005	N HORIZONTAL WELL	Active	WL			72 GPM	Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*